

Reference No: **F/430/245/BSCL**

Date: **27.04.2021**

CORRIGENDUM - 1

Name of the work: Request for Proposal (RFP) for Construction of ICCB Building (B+G+5 floors) including utility services under Smart City Mission on Item Rate basis for remaining work.

NIT NO.: BSCL/ICCCB/2021/53 dated 15/04/2021

The response to prebid queries is being uploaded and published on <https://www.eproc2.bihar.gov.in> and <http://www.smartcitybhagalpur.org> with this corrigendum.

The other terms and conditions mentioned in RFP remain unchanged.



Chief Executive Officer,
Bhagalpur Smart City Limited.

Bhagalpur Smart City Limited

Prebid query Construction of ICCB Building (B+G+5 floors) including utility services under Smart City Mission on Item Rate basis for remaining work
NIT No. - BSCL/ICCCB/2021/53

Sr. No.	RFP Page No.	Clause No.	Description as per RFP	Queries / Suggestions	Clarification
1	283	Bill of Quantity	329. Supplying and fixing single wall mounted 18/22-watt LED type batten fitting complete with electronic driver and LED tube etc directly on wall/ ceiling including connections with 1.5 sq.mm FR PVC insulated copper conductor and earthing the body etc. as required.	Request you mention basic technical parameters e.g. – System Lumen output, System Efficacy, Color Temperature, THD, Power Factor, Dimensions, warranty etc.	As per RFP
2	283	Bill of Quantity	330. Supplying and fixing recess mounted 18-watt LED vertical downlighter complete with all accessories and replaceable electronic driver, directly on false ceiling including connection with 1.5 sq.mm FR PVC insulated copper conductor cable and earthing the body etc. as required.	Request you mention basic technical parameters e.g. – System Lumen output, System Efficacy, Color Temperature, THD, Power Factor, Dimensions, warranty etc.	As per RFP
3	283	Bill of Quantity	331. Supplying and fixing indoor recess mounting 36-watt LED flat panel luminaire suitable for Armstrong / grid ceiling and complete with electronic driver etc. directly on false ceiling including connection with 1.5sq. mm FR PVC insulated copper conductor cable and earthing the body etc. as required.	Request you mention basic technical parameters e.g. – System Lumen output, System Efficacy, Color Temperature, THD, Power Factor, Dimensions, warranty etc.	As per RFP
4	285	Bill of Quantity	348. Supplying and fixing following Retrofit CFL type street light fitting with sheet aluminium housing, clear acrylic cover and all accessories including Retrofit CFL lamp etc. on pole/building including connection with FR PVC insulated copper conductor cable and earthing the	Request you to consider LED fitting against CFL and mention basic technical parameters e.g. – System Lumen output, System Efficacy, Color Temperature, THD, Power Factor, Dimensions, IP &IK ratings, warranty etc.	As per RFP
5	285	Bill of Quantity	349. Supplying and fixing following Retrofit CFL type street light fitting with sheet aluminium housing, clear acrylic cover and all accessories including Retrofit CFL lamp etc. on pole / building including connection with FR PVC insulated copper conductor cable and earthing the	Request you to consider LED fitting against CFL and mention basic technical parameters e.g. – System Lumen output, System Efficacy, Color Temperature, THD, Power Factor, Dimensions, IP & IK ratings, warranty etc.	As per RFP

Sr. No.	RFP Page No.	Clause No.	Description as per RFP	Queries / Suggestions	Clarification
6	285	Bill of Quantity	350. Supplying and fixing 90-watt LED type FLOOD light with die cast aluminium housing for ingress protection of IP65 and complete with all accessories etc and connection with FR PVC insulated copper conductor cable and earthing the body etc. as required.	Request you to mention basic technical parameters e.g. – System Lumen output, System Efficacy, Color Temperature, THD, Power Factor, Dimensions, IK ratings, warranty etc. Request you to consider 90-100Watt against the same.	As per RFP
7	20	4.5 A (a)	The contractor/firm must have achieved a minimum annual financial turnover equal to 50% of estimated cost in any one financial year during last five completed financial years (from 2015-16 to 2019-20).	In the mentioned clause we had a doubt about the indexing value that is mentioned in all building construction department tender of bihar government: in other departments , the clause states turnover will be indexed at the rate of 8% for a year. We want to know weather the clause is not mentioned intentionally or has there been some error. So, we are requesting you to kindly look into the above mentioned issues and clarify/amend the same.	Escalation factor given in para-15 of Appendix to ITB is applicable for computing base value of annual financial turnover.

Sd/-
Chief Executive Officer,
Bhagalpur Smart City Limited